

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 3225-0935:110 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Nailor Industries, 4714 Winfield, Houston TX 77039  
Contact: John Young (281) 590-1172 Fax (281) 590-3086

DESIGN: Models 1271C-1 and 1271C-2 fire rated dampers. Refer to listee's data sheet for detailed product description and operational considerations.

<u>Width</u>		<u>Height</u>	
<i>Min.</i>	<i>Max.</i>	<i>Min.</i>	<i>Max.</i>
8"	24"	8"	24"

RATING: 1 Hour

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as fire dampers for use with listee's listed fire damper operators.

NOTE: Refer to CSFM Listing No. 3230-0935:111 for leakage rated dampers.

02-26-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 20, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager